

(JA/122)

FORT00294571

JA/122

FORT00294571

Grenfell Tower log (Compiled 5.15 a.m 17th June 2017)

Wednesday 14th June 2017

Telephone call from Amir Fardouee (RBKC on call dangerous structures surveyor) requesting assistance- around 5.00 a.m Large fire in Grenfell Road

Arrived at site 6.00a.m/6.30a.m – took over from Amir

Fire fighting in progress. Request for plans of building

Thursday 15th June 2017

Friday 16th June

Arrived at office e-mailed Chief Executive Nicholas Holgate to request 10 minute meeting. Confirmed meeting for 8.00a.m.

Produced agenda (Attached)

Post meeting contacted Barbara Lane Arup engineers to ask if they could be retained by RBKC and to meet me on site. Contacted President of LDSA Anthony Oloyede to have alternative cover for Dangerous Structures operation by another Borough if necessary. Contacted Richard Mills Assistant Commissioner LFB (Incident Commander) in relation to discussion about conflict of interest.

Attended Gold Meeting at RBKC 10.00.

Went to site for 11.30. Jose Anon RBKC on site from 9.00a.m

Met Jan Andersen HSE and Arup Structural Engineers and Fire Engineer.

Spoke to Richard Mills

Attended 1.00 p.m Tactical Control Group. Conflict of interest raised. Confirmed would need to take higher.

As part of information gathering for support of Structural Analysis requested photos taken by LFB on Thursday 15th June of floors 13 to 23 of any exceptions from what I had seen/taken on inspection of tower Weds 14th June. One of LFB said they would go up and take photos now so up to date- I also asked that position of all photos to be logged.

Around 2.30p.m photos provided to engineers to view on tablet. Problem noticed re failed column on floor 13. Requested view on larger screen- once area cleared went

to tent. Once seen on large screen (red flag) concern that there could be collapse of floors above and below 13th floor in vicinity of the corner. Called incident commander- advised him that all personnel should be withdrawn from in and around the building.

Saturday 17th June 2017 17.32 control of all dangerous structures operations for Grenfell handed to Harrow Building Control

17th and 18th June e-mailed Met Police with all information/offers of help etc relevant to the dangerous structures case.