

(JA/19)

Barbara Lane-Walls

Tina Donoghue

From: Barbara Lane <Barbara.Lane@arup.com>
Sent: 14 June 2017 16:17
To: Allen, John: CP-Plan: RBKC
Cc: CHARLES.ROMEYER@london-fire.gov.uk
Subject: walls

No reply required.

Are they insitu or precast?


Have they moved significantly?

Risk then becomes buckling, particularly if slab can no longer restrain the walls.

If they are loadbearing this is a concern.

Barbara

Dr Barbara Lane FREng CEng



Technology Group leader - UKMEA Board

Arup
13 Fitzroy Street
London W1T 4BO
d [REDACTED]
m [REDACTED]
www.arup.com

Electronic mail messages entering and leaving Arup business systems are scanned for viruses and acceptability of content